



**BIDS AND AWARDS COMMITTEE**

2330 Roxas Boulevard, Pasay City  
Tel. Nos.: 834-4823; Fax No.: 831-9584  
Email: bac.secretariat@dfa.gov.ph

**SUPPLEMENTAL / BID BULLETIN No. 3**

Project : Emergency Rehabilitation of DFA OCA-ASEANA's Sewage Treatment Plant (STP) with One-Year Operation and Maintenance  
Reference : PB-IN-01-2024  
ABC : PhP 11,232,000.00  
Date : 30 July 2024


This **Supplemental/Bid Bulletin** is issued to inform prospective bidders of the following clarifications to the Scope of Works of the Project:

1. Item IV.2 of the Technical Specifications (**Treatment and Performance Efficiency**)

The STP will be able to produce effluent with qualities conforming to the DENR-EMB General Effluent Standards (GES) for "**Class SB**" Inland Water (based from DAO Administrative Order No. 08 series of 2016 and Order No. 19 series of 2021) as shown in the table below:

Parameters	(Class SB)	Units
BOD	30	mg/L
Color (True)	100	TCU
COD	60	mg/L
TSS	70	mg/L
Oil and Grease	5	mg/L
Fecal Coliforms (DAO-19-2021)	200	MPN/100mL
Total Coliforms	3,000	MPN/100mL
pH (range)	6.5-9.0	-
Ammonia as NH <sub>3</sub> -N (DAO-19-2021)	3	mg/L
Nitrates as NO <sub>3</sub> -N	20	mg/L
Phosphates (DAO-19-2021)	2	mg/L
Surfactants (MBAS)	3	mg/L

For the information and guidance of all concerned.

  
**EDGAR B. BADAJOS**  
Chairperson  
Bids and Awards Committee